



Lead and Copper in Drinking Water Sampling

Acelero Learning

144 Dr. James Parker Blvd. Red Bank, NJ 07701

**Inspection Company:
Environmental Testing Services LLC.
619 Wills Ave.
Deptford, NJ 08096**

**Laboratory:
Accurate Analytical Testing, LLC.
30105 Beverly Road,
Romulus MI 48174**

Lead in Drinking Water Sampling Date:

**First Inspection: March 21st, 2022
Follow up Inspection: April 14th, 2022**

**Licensed State Lead Inspector
Risk Assessor
Michael Stefkovic (License # NJ 034560)**

April 14th, 2022

Acelero Learning
144 Dr. James Parker Blvd,
Red Bank NJ 07701

**Re: Lead and Copper in Drinking Water Sampling
144 Dr. James Parker Blvd. Red Bank, NJ 07701.**

Dear Mrs. Urbanski:

Environmental Testing Services, LLC. provided water testing for lead on March 21st, 2022 and April 14th, 2022

The purpose of this project was to sample the daycare's drinking water for the presence of lead and copper. Only first draw samples were collected during this inspection. Second draw water testing will be done if the first draw test show amounts exceeding the EPA limits. The locations of each testing location were given to the inspector as to where the use of each water sources are frequently used.

Based on the findings of the testing, the water is acceptable for human consumption at all locations tested.

Sample analysis results and the chain of custody are attached to this report.

If you should have any questions, please feel free to contact us at 866-226-2114

Sincerely,



Michael Stefkovic,
President

Water Samples and Action Levels

The client was instructed by the inspector prior to the inspection to not to use any water source for at least six (6) hours before the inspection. The water samples were collected in 250 ml bottles. The samples were then transported to EMSL Analytical, Inc., a New Jersey Department of Environmental Protection (NJ DEP) certified laboratory for the analysis of the drinking water.

*The Action Levels that are determined from the EPA: "The concentration of lead or copper in tap water which determines whether a system may be required to install corrosion control treatment, collect water quality parameter samples, collect source water samples, replace lead service lines, and/or deliver public education about lead. The action level for lead is 0.015 mg/L or 15 ppb. The action level for copper is 1.3 mg/L or 1300 ppb." **For water**, 1 ppm = approximately 1 mg/L (also written as mg/l) of contaminant in water, and 1 ppb = 1 ug/L (also written as ug/l). A measurement of 6 mg/L is the same as 6 ppm or 6,000 ppb, which is equal to 6,000 ug/L.*

The results from the lab are given in ug/L.

Results of the sampling found all locations fell below the following thresholds of 15 ppb or 15 ug/L. for Lead and 1300 PPM or 1300 ug/L for Copper with regard to lead and copper.

Wipe Sample	Sampling Location Description	Laboratory Results LEAD (ug/L)	Laboratory Results COPPER (ug/L)	Pass/Fail
1	See Lab report			PASS
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
<ol style="list-style-type: none"> 1. The action level for lead is 0.015 mg/L or 15 ppb or 15ug/L. 2. The action level for copper is 1.3 mg/L or 1300 ppb or 1300 ug/L. 				

ND - indicates that the analyte was not detected at the reporting limit

LAB Results

(Lead in water lab report) March 21st, 2022



30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : Environmental Testing Services 619 Wills Ave. Deptford, NJ 08096 Attn : Mike Stefkovic Email : lead@ets-enviro.com Phone : 215-432-4468 Fax :	AAT Project : 779247 Sampling Date : 03/21/2022 Date Received : 03/26/2022 Date Analyzed : 03/29/2022 Date Reported : 03/30/2022 WSSN :
Client Project : ACELERO Collected By:	
Project Location : 144 DR JAMES PARKER BLVD RED BANK NJ	

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead µg/L (ppb)	Reporting Limit	Pb Threshold
7287906	A1	KIT SINK	PB CU		14.0	1.0	Below
7287907	A2	1FL FT CLASS SINK BS	PB CU		1.2	1.0	Below
7287908	A3	1FL FT CLASS BATH SINK	PBCU		<1.0	1.0	Below
7287909	A4	2FL CLASS 1 SINK	PBCU		<1.0	1.0	Below
7287910	A5	2FL CLASS 1 BATH SINK L	PB CU		1.0	1.0	Below
7287911	A6	2FL CLASS 2 BATH SINK R	PB CU		<1.0	1.0	Below
7287912	A7	2FL HALL BATH SINK	PB CU		<1.0	1.0	Below

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is 1 µg/L (ppb) and for Cu is 1.5 µg/L (ppb). For true values assume (2) significant figures. AAT internal SOP 5230. The method and batch QC are acceptable unless otherwise stated.
EPA Regulatory Limits: 15 µg/L for Pb and 1300 µg/L for Cu
The laboratory operates in accord with NELAP guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996
Date Printed: 03/30/2022

AAT Project: 779247

LAB Results

(Copper in water lab report) March 21st, 2022



30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

Client : Environmental Testing Services 619 Wills Ave. Deptford, NJ 08096 Attn : Mike Stefkovic Email : lead@ets-enviro.com Phone : 215-432-4468 Fax :	AAT Project : 779247 Sampling Date : 03/21/2022 Date Received : 03/28/2022 Date Analyzed : 03/29/2022 Date Reported : 03/30/2022 WSSN :
Client Project : ACELERO Collected By : Project Location : 144 DR JAMES PARKER BLVD RED BANK NJ	

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper µg/L (ppb)	Cu Threshold
7287906	A1	KIT SINK	PB CU		1,323.2	Above
7287907	A2	1FL FT CLASS SINK B6	PB CU		205.6	Below
7287908	A3	1FL FT CLASS BATH SINK	PBCU		226.6	Below
7287909	A4	2FL CLASS 1 SINK	PBCU		285.8	Below
7287910	A5	2FL CLASS 1 BATH SINK L	PB CU		320.3	Below
7287911	A6	2FL CLASS 2 BATH SINK R	PB CU		88.3	Below
7287912	A7	2FL HALL BATH SINK	PB CU		132.6	Below

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 1 µg/L (ppb) and for Cu is 1.5 µg/L (ppb). For true values assume (2) significant figures. AAT Internal SOP 8230. The method and batch QC are acceptable unless otherwise stated.
EPA Regulatory Limits: 15 µg/L for Pb and 1300 µg/L for Cu
The laboratory operates in accord with NELAP guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample date apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 03/30/2022

AAT Project: 779247

Chain of Custody March 21st, 2022



30105 BEVERLY RD.
ROMULUS MI 48174
(734) 699-LABS (5227)
FAX: (734) 699-9407
Website: www.accurate-test.com
Email: customersupport@accurate-test.biz

SUBMITTING COMPANY
Environmental Testing Services LLC
619 Wils Ave. Deptford, NJ 08098

CONTACT INFORMATION
Office: 866-226-2114
Fax:
Email 1: info@ets-services.com
Email 2: services@ets-services.com

PROJECT NUMBER: Accelero SAMPLING DATE: 3/21/22

PROJECT ADDRESS: 144 Dr. James Parker Blvd

PERSONAL COLLECTOR'S NAME: Red Bank, NJ

REQUESTED ANALYSIS: Drinking Water

LEAD COPPER BOTH

TURNAROUND TIME (please check one)
 24 Hour () 48 Hour App
 72 Hour () 5 Days ()

If no TAT is indicated, default is 5 Days

CLIENT SAMPLE ID	DESCRIPTION	SAMPLE TYPE or PURPOSE *	TIME	VOLUME	CLIENT COMMENTS
A1	Kitchen Sink	Pb/Cu		250	SAMPLES SHIPPED
A2	1st FL FT Class Sink (B)	Pb/Cu		250	SAMPLES ACIDIFIED Y N
A3	1st FL FT Class Bath Sink	Pb/Cu		250	
A4	2nd FL Class 1 Sink	Pb/Cu		250	NY STATE SAMPLES (Check here)
A5	2nd FL Class 1 Bath Sink (L)	Pb/Cu		250	SEALS INTACT Y N
A6	2nd FL Class 2 Bath Sink (R)	Pb/Cu		250	CONTAINERS LABELED Y N
A7	2nd FL Hall Bath Sink	Pb/Cu		250	RECYD & ACCEPTED Y N
					SAMPLES ACIDIFIED Y N
					LAB REMARKS
					LAB PROJECT NUMBER
					DATE
					TIME
					AM
					PM

[Handwritten Signature]

SAMPLES RECEIVED BY
[Handwritten Signature]

By submitting samples to AAT, the client agrees to AAT's terms and conditions. AAT is not responsible for shipping delays.

* Sample Type or Purpose -- Key: Routine Distribution (RD) Check Sample (CS) Raw Water (RW) Process Water (PW) Investigation Number (IN)

LAB Results

(Copper in water lab report) April 14th, 2022



30105 Beverly Road
 Romulus, MI 48174
 Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : Environmental Testing Services 619 Willis Ave. Deptford, NJ 08096 Attn : Mike Stefkovic Email : lead@ets-enviro.com Phone : 215-432-4468 Fax :	AAT Project : 787368 Sampling Date : 04/14/2022 Date Received : 04/19/2022 Date Analyzed : 04/20/2022 Date Reported : 04/20/2022 WSSN :
Client Project : ACELERO Collected By:	
Project Location : 144 DR JAMS PARKER BLVD FREETOLD NJ	

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead µg/L (ppb)	Reporting Limit	Pb Threshold
7357630	1	KITCHEN SINK	CU	0	<1.0	1.0	Below

Analyst Signature

Joseph Kenwabikise

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is 1 µg/L (ppb) and for Cu is 1.5 µg/L (ppb). For true values assume (2) significant figures. AAT Internal SOP 5230. The method and batch QC are acceptable unless otherwise stated.
 EPA Regulatory Limits: 15 µg/L for Pb and 1300 µg/L for Cu
 The laboratory operates in accord with NELAP guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample date apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996
 Date Printed: 04/20/2022

AAT Project: 787368

Chain of Custody April 14th, 2022



30105 BEVERLY RD.
ROMULUS MI 48174
(734) 699-LABS (5227)
FAX: (734) 699-8407

Website: www.accurate-test.com
Email: customersupport@accurate-test.biz



SUBMITTING COMPANY
Environmental Testing Services LLC
619 Mills Ave. Dupont, NJ 08098

CONTACT INFORMATION

Office: 866-226-2114
Fax:
Email 1: info@ets-services.com
Email 2: business@ets-services.com

PROJECT NUMBER: Accelero SAMPLING DATE: 4/14/22		TURNAROUND TIME (please check one) 24 Hour () 48 Hour (XX)	
PROJECT ADDRESS: 144 Dr. James Parker Blvd PERSON COLLECTING THE SAMPLE: Fredrick NJ		72 Hour () 5 Days () <small>If no TAT is indicated, default is 5 Days</small>	
REQUESTED ANALYSIS Drinking Water <small>WSSN</small>		LEAD <input type="checkbox"/> COPPER <input checked="" type="checkbox"/> BOTH <input type="checkbox"/>	
LAB ID # 7851020	CLIENT SAMPLE ID 1	DESCRIPTION Kitchen Sink	VOLUME 250 ml
SAMPLE TYPE or PURPOSE * CU		CLIENT COMMENTS SAMPLES SHIPPED SAMPLES ACIDIFIED Y N	
NY STATE SAMPLES <input type="checkbox"/> <small>(Check here)</small>			
SAMPLE CONDITION SEALS INTACT Y N CONTAINERS LABELED Y N REC'D & ACCEPTED Y N SAMPLES ACIDIFIED Y N			
LAB REMARKS <p style="text-align: center; font-size: 2em;">2009</p>			
SAMPLES RELINQUISHED BY 		SAMPLES RECEIVED BY 	
DATE 4/19/22		TIME AM	
LAB PROJECT NUMBER 78708		DATE 4/14/22	
		TIME AM	

By submitting samples to AAT, the client agrees to AAT's terms and conditions.
AAT is not responsible for shipping delays.

* Sample Type or Purpose -- Key: Routine Distribution (RD) Check Sample (CS) Raw Water (RW) Process Water (PW) Investigation Number (IN)

FORM: Drinking Water

LEAD CERTIFICATIONS
ETS LLC.
STATE OF NJ

New Jersey Department of Health

MICHAEL STEFKOVIC



Permit No.: 034560
ID No.: 013780
Expires: 8/10/2022

Authorization Signature: 
Christina Tau, MD, M.P.H., Assistant Commissioner

Inspector/Risk Assessor

Lead Identification Permit

Certificate of Completion

awarded to
Michael Stefkovic
for successfully completing the prescribed course of study in

**New Jersey Lead Inspector/Risk Assessor Refresher
Housing and Public Buildings**
in accordance with EPA, HUD, and NJDH Guidelines

presented by
ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, New Jersey 08110
(856) 665-3449

<u>1/15/21</u> Course Date	<u>1/15/21</u> Exam Date	<u>1/15/23</u> Expiration Date
<u>Not Provided</u> Social Security Number	<u>ACC-0121-18-007</u> Certificate Number	 Mark K. Schlager Training Director



PHILIP D. MURPHY
Governor
LOCATION
101 S BROAD ST
TRENTON NJ 08608

STATE OF NEW JERSEY
DEPARTMENT OF COMMUNITY AFFAIRS
DIVISION OF CODES AND STANDARDS
LEAD HAZARD UNIT

I.T. GOVERNOR SHEILA Y. OLIVER
Commissioner
MAILING ADDRESS
101 S BROAD ST
TRENTON NJ 08618

Certificate - Lead Evaluation Contractor

RECERTIFIED

This is to certify that the Department of Community Affairs has certified

ENVIRONMENTAL TESTING SERVICES
619 WILLS AVE.
DEPTFORD NJ 08096

To act as a Lead Evaluation Contractor on the following Projects

Residential
Public Buildings

Cert #: 00531-E
Effective Date: 8/1/2020
Expiration Date: 7/31/2022
Certificate Type: 2 YEAR



AIHA Laboratory Accreditation Programs, LLC

acknowledges that

Accurate Analytical Testing, LLC

30105 Beverly Road, Romulus, MI 48174

Laboratory ID: LAP-100986

along with all premises from which key activities are performed, as listed above, has fulfilled the requirements of the AIHA Laboratory Accreditation Programs (AIHA LAP), LLC accreditation to the ISO/IEC 17025:2017 international standard, General Requirements for the Competence of Testing and Calibration Laboratories in the following:

LABORATORY ACCREDITATION PROGRAMS

- | | | |
|-------------------------------------|-----------------------------------|---|
| <input type="checkbox"/> | INDUSTRIAL HYGIENE | Accreditation Expires: |
| <input checked="" type="checkbox"/> | ENVIRONMENTAL LEAD | Accreditation Expires: September 01, 2023 |
| <input type="checkbox"/> | ENVIRONMENTAL MICROBIOLOGY | Accreditation Expires: |
| <input type="checkbox"/> | FOOD | Accreditation Expires: |
| <input type="checkbox"/> | UNIQUE SCOPES | Accreditation Expires: |

Specific Field(s) of Testing (FoT)/Method(s) within each Accreditation Program for which the above named laboratory maintains accreditation is outlined on the attached Scope of Accreditation. Continued accreditation is contingent upon successful on-going compliance with ISO/IEC 17025:2017 and AIHA LAP, LLC requirements. This certificate is not valid without the attached Scope of Accreditation. Please review the AIHA LAP, LLC website (www.aihaaccreditedlabs.org) for the most current Scope.

Cheryl O. Morton

Cheryl O Morton
Managing Director, AIHA Laboratory Accreditation Programs, LLC

Revision 19.1: 07/28/2021

Date Issued: 08/31/2021