



Lead and Copper in Drinking Water Sampling

Acelero Learning

59 Broad St, Freehold, NJ 07728

**Inspection Company:
Environmental Testing Services LLC.
619 Wills Ave.
Deptford, NJ 08096**

**Laboratory:
Accurate Analytical Testing, LLC.
30105 Beverly Road,
Romulus MI 48174**

**Lead in Drinking Water Sampling Date:
March 30th, 2022**

**Licensed State Lead Inspector
Risk Assessor
Matthew Stefkovic (License # NJ 036151)**



March 30th, 2022

Acelero Learning
59 Broad St.
Freehold, NJ 07728

**Re: Lead and Copper in Drinking Water Sampling
59 Broad St, Freehold, NJ 07728.**

Dear Mr. Urbanski:

Environmental Testing Services, LLC. provided water testing for lead on March 30th, 2022.

The purpose of this project was to sample the daycare's drinking water for the presence of lead and copper. Only first draw samples were collected during this inspection. Second draw water testing will be done if the first draw test show amounts exceeding the EPA limits. The locations of each testing location were given to the inspector as to where the use of each water sources are frequently used.

Based on the findings of the testing, the water is acceptable for human consumption at all locations tested.

Sample analysis results and the chain of custody are attached to this report.

If you should have any questions, please feel free to contact us at (856) 432-4468

Sincerely,

A handwritten signature in black ink, appearing to read "Matthew Stefkovic", is written over a light gray rectangular background.

Matthew Stefkovic,
Risk Assessor

Water Samples and Action Levels

The client was instructed by the inspector prior to the inspection to not to use any water source for at least six (6) hours before the inspection. The water samples were collected in 250 ml bottles. The samples were then transported to EMSL Analytical, Inc., a New Jersey Department of Environmental Protection (NJ DEP) certified laboratory for the analysis of the drinking water.

*The Action Levels that are determined from the EPA: "The concentration of lead or copper in tap water which determines whether a system may be required to install corrosion control treatment, collect water quality parameter samples, collect source water samples, replace lead service lines, and/or deliver public education about lead. The action level for lead is 0.015 mg/L or 15 ppb. The action level for copper is 1.3 mg/L or 1300 ppb." **For water**, 1 ppm = approximately 1 mg/L (also written as mg/l) of contaminant in water, and 1 ppb = 1 ug/L (also written as ug/l). A measurement of 6 mg/L is the same as 6 ppm or 6,000 ppb, which is equal to 6,000 ug/L.*

The results from the lab are given in ug/L.

Results of the sampling found all locations fell below the following thresholds of 15 ppb or 15 ug/L. for Lead and 1300 PPM or 1300 ug/L for Copper with regard to lead and copper.

Wipe Sample	Sampling Location Description	Laboratory Results LEAD (ug/L)	Laboratory Results COPPER (ug/L)	Pass/Fail
1	See Lab report			PASS
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
<ol style="list-style-type: none"> 1. The action level for lead is 0.015 mg/L or 15 ppb or 15ug/L. 2. The action level for copper is 1.3 mg/L or 1300 ppb or 1300 ug/L. 				

ND - indicates that the analyte was not detected at the reporting limit

LAB Results

(Lead in water lab report)



30105 Beverly Road
Romulus, MI 48174
Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client : Environmental Testing Services 619 Mills Ave. Deptford, NJ 08096 Attn : Mike Stefkovic Email : lead@ets-enviro.com Phone : 215-432-4468 Fax :	AAT Project : 781512 Sampling Date : 03/30/2022 Date Received : 04/01/2022 Date Analyzed : 04/05/2022 Date Reported : 04/05/2022 WSSN :
Client Project : ACELERO Collected By: Project Location : 59 BROAD ST FREEHOLD NJ 07728	

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead µg/L (ppb)	Reporting Limit	Pb Threshold
7305483	B1	MEN LEFT SINK	DRINKING		1.2	1.0	Below
7305484	B2	WOMEN RIGHT SINK	DRINKING		1.3	1.0	Below

Analyst Signature

Andrew Theys

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 1 µg/L (ppb) and for Cu is 1.5 µg/L (ppb). For the values assume (2) significant figures. AAT Internal SOP S230. The method and batch QC are acceptable unless otherwise stated.
 EPA Regulatory Limits: 15 µg/L for Pb and 1300 µg/L for Cu
 The laboratory operates in accord with NELAP guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996
 Date Printed: 04/05/2022

AAT Project: 781512

LAB Results

(Copper in water lab report)



30105 Beverly Road
 Romulus, MI 48174
 Ph: 734-629-8161; Fax: 734-629-8431

Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5

Client : Environmental Testing Services 619 Wills Ave. Deptford, NJ 08096 Attn : Mike Stefkovic Email : lead@ets-enviro.com Phone : 215-432-4458 Fax :	AAT Project : 781512 Sampling Date : 03/30/2022 Date Received : 04/01/2022 Date Analyzed : 04/05/2022 Date Reported : 04/05/2022
Client Project : ACELERO Collected By : Project Location : 59 BROAD ST FREEHOLD NJ 07728	WSSN :

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper µg/L (ppb)	Cu Threshold
7305483	B1	MEN LEFT SINK	DRINKING		340.7	Below
7305484	B2	WOMEN RIGHT SINK	DRINKING		314.7	Below

Analyst Signature

Andrew Theys

ND = Not Detected, N/A = Not Available, RL = Reporting Limit, The Analytical Reporting Limit for Pb is: 1 µg/L (ppb) and for Cu is 1.5 µg/L (ppb).
 For true values assume (2) significant figures. AAT Internal SOP 8230. The method and batch QC are acceptable unless otherwise stated.
 EPA Regulatory Limits: 15 µg/L for Pb and 1300 µg/L for Cu
 The laboratory operates in accord with NELAP guidelines and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted. All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 15 days following report date.



NY State DOH ELAP - Lab ID # 11864, Michigan State Lab # 9996

Date Printed: 04/05/2022

AAT Project: 781512

Chain of Custody

CONTACT INFORMATION
SUBMITTING COMPANY
 Environmental Testing Services LLC
 619 Wills Ave. Deptford, NJ 08098
 Office: 866-226-2114
 Fax: 866-226-2114
 Email 1: info@ets-labs.com
 Email 2: billing@ets-labs.com

PROJECT INFORMATION
 30105 BEVERLY RD.
 ROMULUS MI 48174
 (734) 699-LABS (5227)
 FAX: (734) 699-8407
 Website: www.accurate-labs.com
 Email: customersupport@accurate-labs.biz



REQUESTED ANALYSIS
Drinking Water
 WSSN

TURNAROUND TIME (please check one)
 24 Hour () 48 Hour ()
 72 Hour () 5 Days ()
If no TAT is indicated, default is 5 Days

LEAD
COPPER
BOTH

PROJECT NUMBER: Acelero
SAMPLING DATE: 3/30/22
PROJECT ADDRESS: 59 Broad St, Freshhold, NJ 07728
PERSON COLLECTING THE SAMPLES:

LAB ID #	CLIENT SAMPLE ID	DESCRIPTION	SAMPLE TYPE OR PURPOSE *	TIME	VOLUME	CLIENT COMMENTS
7305483	B1	Men Left Sink	Drinking Water		250	SAMPLES SHIPPED SAMPLES ACIDIFIED Y N
	B2	Woman Right Sink	Drinking Water		250	SAMPLES SHIPPED SAMPLES ACIDIFIED Y N
NY STATE SAMPLES: (Check here) SEALS INTACT Y N CONTAINERS LABELED Y N REC'D & ACCEPTED Y N SAMPLES ACIDIFIED Y N LAB REMARKS						
LAB PROJECT NUMBER: 781572 DATE: 4/12/22 TIME: 9 AM						

SAMPLES RELINQUISHED BY: [Signature]
SAMPLES RECEIVED BY: [Signature]
 Investigation Number (IN):

* Sample Type or Purpose - Key: Routine Distribution (RD) Check Sample (CS) Raw Water (RW) Process Water (PW) Investigation Number (IN)
 By submitting samples to AAT, the client agrees to AAT's terms and conditions.
 AAT is not responsible for shipping delays.

LEAD CERTIFICATIONS
ETS LLC.
STATE OF NJ

New Jersey Department of Health
MATTHEW D STEFKOVIC



Permit No.: 036151
ID No.: 036151
Expires: 2/22/2023

Authorization Signature: *Christina Tan*
Christina Tan, MD, M.P.H., Assistant Commissioner
Inspector/Risk Assessor

Certificate of Completion

awarded to
Matthew Stefkovic
for successfully completing the prescribed course of study in
**New Jersey Lead Inspector/Risk Assessor,
Housing and Public Buildings**
in accordance with EPA and HUD Guidelines

presented by
ACCESS TRAINING SERVICES, INC.
7921 River Road, Pennsauken, New Jersey 08110
(856) 665-3449

8/31-9/4/20
Course Date

9/4/20
Exam Date

9/4/22
Expiration Date

N/A
Social Security Number

ACC-0920-17-007
Certificate Number

Mark E. Schlager
Mark E. Schlager
Training Director



PHILIP D. MURPHY
Governor
LOCATION
101 S BROAD ST
TRENTON NJ 08608

STATE OF NEW JERSEY
DEPARTMENT OF COMMUNITY AFFAIRS
DIVISION OF CODES AND STANDARDS
LEAD HAZARD UNIT

I.T. GOVERNOR SHEILA Y. OLIVER
Commissioner
MAILING ADDRESS
101 S BROAD ST
TRENTON NJ 08618

Certificate - Lead Evaluation Contractor

RECERTIFIED

This is to certify that the Department of Community Affairs has certified

ENVIRONMENTAL TESTING SERVICES
619 WILLS AVE.
DEPTFORD NJ 08096

To act as a Lead Evaluation Contractor on the following Projects

Residential
Public Buildings

Cert #: 00531-E
Effective Date: 8/1/2020
Expiration Date: 7/31/2022
Certificate Type: 2 YEAR

Accredited Lab for processing

Accurate Analytical Testing, LLC
30105 Beverly Road,
Romulus MI 48174

Laboratory ID: 100986

