



**ENVIRONMENTAL  
TESTING SERVICES LLC.**

## **Lead and Copper in Drinking Water Sampling**

**Acelero Learning**

**2239 US 1 South, North Brunswick, NJ 08902**

**Inspection Company:  
Environmental Testing Services LLC.  
619 Wills Ave.  
Deptford, NJ 08096**

**Laboratory:  
Accurate Analytical Testing, LLC.  
30105 Beverly Road,  
Romulus MI 48174**

**Lead in Drinking Water Sampling Date:  
February 20th, 2019**

**Licensed State Lead Inspector  
Risk Assessor  
Michael Stefkovic (License # NJ 032563)**



February 20th, 2019

Acelero Learning  
2239 US 1 South,  
North Brunswick, NJ 08902

Re: **Lead and Copper in Drinking Water Sampling**  
**2239 US 1 South, North Brunswick, NJ 08902.**

Dear Mr. Urbanski:

Environmental Testing Services, LLC. provided water testing for lead on February 20th, 2019.

The purpose of this project was to sample the daycare's drinking water for the presence of lead and copper. Only first draw samples were collected during this inspection. Second draw water testing will be done if the first draw test show amounts exceeding the EPA limits. The locations of each testing location were given to the inspector as to where the use of each water sources are frequently used.

Based on the findings of the testing, the water is acceptable for human consumption at all locations tested.

Sample analysis results and the chain of custody are attached to this report.

If you should have any questions, please feel free to contact us at (856) 432-4468

Sincerely,

A handwritten signature in black ink, appearing to read "Michael Stefkovic", is written over a faint, light-colored signature line.

Michael Stefkovic,  
President

## Water Samples and Action Levels

The client was instructed by the inspector prior to the inspection to not to use any water source for at least six (6) hours before the inspection. The water samples were collected in 250 ml bottles. The samples were then transported to EMSL Analytical, Inc., a New Jersey Department of Environmental Protection (NJ DEP) certified laboratory for the analysis of the drinking water.

*The Action Levels that are determined from the EPA: "The concentration of lead or copper in tap water which determines whether a system may be required to install corrosion control treatment, collect water quality parameter samples, collect source water samples, replace lead service lines, and/or deliver public education about lead. The action level for lead is 0.015 mg/L or 15 ppb. The action level for copper is 1.3 mg/L or 1300 ppb." **For water**, 1 ppm = approximately 1 mg/L (also written as mg/l) of contaminant in water, and 1 ppb = 1 ug/L (also written as ug/l). A measurement of 6 mg/L is the same as 6 ppm or 6,000 ppb, which is equal to 6,000 ug/L.*

The results from the lab are given in ug/L.

**Results of the sampling found all locations fell below the following thresholds of 15 ppb or 15 ug/L. for Lead and 1300 PPM or 1300 ug/L for Copper with regard to lead and copper.**

Wipe Sample	Sampling Location Description	Laboratory Results <u>LEAD</u> (ug/L)	Laboratory Results <u>COPPER</u> (ug/L)	Pass/Fail
1	See Lab report			PASS
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
1. The action level for lead is 0.015 mg/L or 15 ppb or 15ug/L. 2. The action level for copper is 1.3 mg/L or 1300 ppb or 1300 ug/L.				

ND - indicates that the analyte was not detected at the reporting limit

# LAB Results



30105 Beverly Road  
 Romulus, MI 48174  
 Ph: 734-629-8161; Fax: 734-629-8431

## Certificate of Analysis: Lead In Drinking Water by EPA Method 200.5

Client: Environmental Testing Services 2021 Hartel Levittown, NJ 19067	AAT Project: 472347 Sampling Date: 02/14/2019 Date Received: 02/19/2019 Date Analyzed: 02/20/2019 Date Reported: 2/20/2019 3:43:14PM
Attn: Mike Stefko Phone: 215-432-4456	Email: lead@ets-enviro.com Fax:
Client Project: ACELERO LEARNING	Collected By: WSSH:
Project Location: 2239 US 1 SOUTH NORTH BRUNSWICK NJ 08902	

Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Lead µg/L (ppb)	Reporting Limit	Pb Threshold
4545043	B1	CLASS 6 BATH SINK 1			3.2	1.0	Below
4545044	B2	OFFICE WATER FOUNTAIN			<1.0	1.0	Below
4545045	B3	CLASS 10 BATH SINK			4.0	1.0	Below
4545046	B4	CLASS 10 OPPOSITE BATH SIN			12.9	1.0	Below
4545047	B5	CLASS 1 SINK LEFT			10.8	1.0	Below
4545048	B6	CLASS 2 SINK LEFT			10.7	1.0	Below
4545049	B7	CLASS 2 OPPOSITE ROOM SIN			2.6	1.0	Below
4545050	B8	CLASS 2 OPPOSITE ROOM BA			3.3	1.0	Below
4545051	B9	CLASS NEXT TO CLASS 2 BAT			23.7	1.0	Above
4545052	B10	CLASS 7 LEFT SINK			5.0	1.0	Below
4545053	B11	CLASS 11 SINK			5.5	1.0	Below
4545054	B12	CLASS 11 HALL ADULT BATH S			37.7	1.0	Above

Analyst Signature

Robert Limmer

ND = Not Detected, NA = Not Available, RL = Reporting Limit. The Analytical Reporting Limit for Pb is 1.0 µg/L (ppb) and for Cu is 1.5 µg/L (ppb).  
 For lead values assume (2) significant figures. AAT Internal SOP 0203. The method used each QC are acceptable unless otherwise stated.  
 EPA Regulatory Limit: 15 µg/L for Pb and 1300 µg/L for Cu

The laboratory operates in accord with NELAP guidelines and holds accreditation under the NJ State DGH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples we received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted.

All Quality control requirements for the samples this report contains have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 30 days following report date.



NY State DGH ELAP - Lab ID # 11864  
 Date Printed: 02/20/2019

AAT Project: 472347



30105 Beverly Road  
 Romulus, MI 48174  
 Ph: 734-629-8161; Fax: 734-629-8431

**Certificate of Analysis: Copper In Drinking Water by EPA Method 200.5**

Client: Environmental Testing Services 2021 Harteel Levittown, NJ 19057	AAT Project: 472347 Sampling Date: 02/14/2019 Date Received: 02/18/2019 Date Analyzed: 02/20/2019 Date Reported: 2/20/2019 3:43:14PM
Attn: Mike Cerkovic      Email: lead@ets-enviro.com Phone: 215-432-4458      Fax:	
Client Project: ACELERO LEARNING      Collected By:	WSSN:
Project Location: 2239 US 1 SOUTH NORTH BRUNSWICK NJ 08902	

Lab Sample ID	Client Code	Sample Description	Purpose	Collection Time	Results Copper µg/L (ppb)	Cu Threshold
4545043	B1	CLASS 6 BATH SINK 1			156.9	Below
4545044	B2	OFFICE WATER FOUNTAIN			564.7	Below
4545045	B3	CLASS 10 BATH SINK			255.6	Below
4545046	E4	CLASS 10 OPPOSITE BATH			437.9	Below
4545047	B5	CLASS 1 SINK LEFT			393.1	Below
4545048	B6	CLASS 2 SINK LEFT			500.2	Below
4545049	B7	CLASS 2 OPPOSITE ROOM			176.2	Below
4545050	B5	CLASS 2 OPPOSITE ROOM			661.9	Below
4545051	B9	CLASS NEXT TO CLASS 2			425.7	Below
4545052	B10	CLASS 7 LEFT SINK			1,212.0	Below
4545053	B11	CLASS 11 SINK			703.2	Below
4545054	B12	CLASS 11 HALL ADULT BAT			1,221.0	Below

Analyst Signature

Robert Limmer

ND = Not Detected, NA = Not Available, RL = Reporting Limit. The Analytical Reporting Limit for Pb is 1.0 µg/L (ppb) and for Cu is 1.5 µg/L (ppb) for the values assume (2) significant figures. AAT Internal SOP 0020. The method used (EPA 200.5) was appropriate unless otherwise stated.  
 EPA Regulatory limits: 15 µg/L for Pb and 1.300 µg/L for Cu.  
 The laboratory complies in accord with NELAP procedures and holds accreditation under the NY State DOH ELAP program. These results are submitted pursuant to AAT, LLC current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. Analytical results relate to the samples as received by the lab. AAT will not assume any liability or responsibility for the manner in which the results are used or interpreted.  
 All Quality control requirements for the samples this report conforms have been met. Sample data apply only to items analyzed. Reproduction of this document other than in its entirety is not authorized by AAT, LLC. Samples are stored for 30 days following report date.



NY State DOH ELAP - Lab ID # 11654

Date Printed: 02/20/2019

AAT Project: 472347



# ACCURATE ANALYTICAL TESTING LLC

1880 INDEPENDENCE ROAD  
BELLEVILLE, MISSOURI 63407  
TEL: 636-335-1925 FAX: 636-335-3407  
WWW.ACCURATE-TEST.COM

**SUBMITTING COMPANY**  
Environmental Testing Services LLC  
2021 Harbri Street  
Levittown, PA 19057  
PO #

**CONTACT INFORMATION**  
Office 215-783-7261  
Fax  
Cell  
Email: Lee@ats-environment.com

PROJECT NUMBER: <b>Accelero Learning</b>	SMPLR DATE: <b>2/14/19</b>	REQUESTED ANALYSIS: <b>LEAD</b>	TURN AROUND TIME
PROJECT ADDRESS: <b>2239 US-1 South</b>		SINGLE WIPE DUST: <b>1</b>	SAME DAY ( ) 48 HOUR ( )
<b>North Brunswick NJ 08902</b>		WATER: <b>(X)</b>	24 HOURS (XX) STD ( )

LAB ID	SAMPLE ID	ROOM USAGE	AREA	CLIENT COMMENTS
51119	B1	CLASS 6 Bath sink 1	250 ML	SAMPLE CONDITION SEALS INTACT Y N PRESERVATIVES Y N CONTAINERS LABELED Y N LAB REMARKS 2009 47737
51120	B2	OFFICE WATER Fountain	250 ML	
51121	B3	CLASS 10 BATH SINK	250 ML	
51122	B4	CLASS 10 OPPOSITE BATH SINK	250 ML	
51123	B5	CLASS 1 SINK LEFT	250 ML	
51124	B6	CLASS 2 SINK LEFT	250 ML	
51125	B7	CLASS 2 OPPOSITE ROOM SINK	250 ML	
51126	B8	CLASS 2 OPPOSITE ROOM BATH SINK	250 ML	
51127	B9	CLASS NEXT TO CLASS 2 BATH SINK	250 ML	
51128	B10	CLASS 7 LEFT SINK	250 ML	
51129	B11	CLASS 11 SINK	250 ML	
51130	B12	CLASS 11 HALL ADJUT BATH SINK	250 ML	

SAMPLES RELINQUISHED BY: *[Signature]*

SAMPLES RECEIVED BY: *[Signature]*

LAB PROJECT NUMBER	TIME
	AM
	AM
	AM

LEAD CERTIFICATIONS  
ETS LLC.  
STATE OF NJ

*New Jersey Department of Health*

**MICHAEL STEFKOVIC**



**Permit No.: 032563**  
**ID No.: 013780**  
**Expires: 8/10/2020**

Authorization Signature: *Christina Tan*  
Christina Tan, MD, M.P.H., Assistant Commissioner

**Inspector/Risk Assessor**

*Lead Identification Permit*

**Certificate of Completion**

awarded to  
**Michael Stefkovic**  
for successfully completing the prescribed course of study in

**New Jersey Lead Inspector/Risk Assessor Refresher  
Housing and Public Buildings**  
in accordance with EPA, HUD, and NJDH Guidelines

presented by  
**ACCESS TRAINING SERVICES, INC.**  
7921 River Road, Pennsauken, New Jersey 08110  
(856) 665-3449

2/20/19 Course Date      2/20/19 Exam Date      2/20/21 Expiration Date  
Not Provided Social Security Number      ACC-0219-18-001 Certificate Number      *Mark K. Schlager* Training Director



PHILIP D. MURPHY  
Governor

STATE OF NEW JERSEY  
DEPARTMENT OF COMMUNITY AFFAIRS  
DIVISION OF CODES AND STANDARDS  
LEAD HAZARD UNIT

Lt. GOVERNOR SHEILA Y. OLIVER  
Commissioner

LOCATION  
101 SOUTH BRIDGE STREET  
TRENTON, NEW JERSEY 08618

MAILING ADDRESS  
PO BOX 821  
TRENTON, NJ 08625-0821

Certificate - Lead Evaluation Contractor

This is to certify that the Department of Community Affairs has

( ) CERTIFIED  
(XX) RECERTIFIED

ENVIRONMENTAL TESTING SERVICES  
619 WILLS AVE.  
DEPTFORD, NJ 08096

To act as a Lead Evaluation Contractor on the following projects

Residential  
Public Buildings

Cert # 00531 E

Effective Date: JUNE 1, 2018

Date of Expiration: MAY 31, 2020

Certificate Type: 2 YEAR

Sincerely,

O. Tex Falajki  
Supervisor of Certification  
Lead Hazard Unit



KLACER (Rev. 01/22/2016)





AIHA Laboratory Accreditation Programs, LLC

acknowledges that

Accurate Analytical Testing, LLC

30105 Beverly Road, Romulus, MI 48174

Laboratory ID: 100956

Along with all premises from which key activities are performed, as listed above, has fulfilled the requirements of the AIHA Laboratory Accreditation Programs (AIHA-LAP), LLC accreditation to the ISO/IEC 17025:2005 international standard, General Requirements for the Competence of Testing and Calibration Laboratories in the following:

LABORATORY ACCREDITATION PROGRAMS

- INDUSTRIAL HYGIENE
- ENVIRONMENTAL LEAD
- ENVIRONMENTAL MICROBIOLOGY
- FOOD
- UNIQUE SCOPES

Accreditation Expires:  
 Accreditation Expires: July 01, 2019  
 Accreditation Expires:  
 Accreditation Expires:

Specific Fields of Testing (FoT) Method(s) within each Accreditation Program for which the above named laboratory maintains accreditation is outlined on the attached Scope of Accreditation. Continued accreditation is contingent upon successful ongoing compliance with ISO/IEC 17025:2005 and AIHA-LAP, LLC requirements. This certificate is not valid without the attached Scope of Accreditation. Please refer to the AIHA-LAP, LLC website ([www.aiahq.com/aihalap](http://www.aiahq.com/aihalap)) for the most current Scope.

*William Witzik*  
 William Witzik, CHS  
 Chairperson, Analytical Accreditation Board

*Cheryl O. Morton*  
 Cheryl O. Morton  
 Managing Director, AIHA Laboratory Accreditation Programs, LLC

Revision 15: 03-30-2016

Date Issued: 03-31-2017